



STATE OF RHODE ISLAND AND PROVIDENCE PLANTATIONS

FIRE SAFETY CODE
BOARD OF APPEAL AND REVIEW
One Capitol Hill
Providence, R.I. 02908-5859

Office (401) 222-3189
FAX (401) 222-1032
TDD# (401) 222-6334

APPROVAL REPORT NO. 03-001

APPLICANT: NoFire Technologies, Inc.
21 Industrial Avenue
Upper Saddle River, NJ 07458

PRODUCT: NoFire A18

DESCRIPTION: NoFire A18 is a non-toxic, non-flammable water-based intumescent coating which, upon exposure to fire, immediately foams and swells to provide an effective insulating heat shield to protect the subsurface base material to which it has been applied. This product may be utilized in complying with flame spread and flame retardant requirements for interior finishes as regulated by the Rhode Island Fire Code.

APPROVALS: NoFire A18 has previously been approved as a flame retardant coating by the Rhode Island Building Commission in Approval Report No. 97-211.

NoFire A18 have also been certified by UL as an approved flame spread product.


NoFire A18 has also been tested and approved for use on U.S. Coast Guard Ships and U.S. Navy Submarines.

BOARD ACTION: NoFire A18 was reviewed by the Fire Safety Code Board of Appeal & Review on September 9, 2003. At that time, in light of the UL and other approvals outlined above, a motion was made by Commissioner Richard and seconded by Commissioner Newbrook to recognize NoFire A18 as an approved non-toxic "Class A" material suitable for installation as flame retardant coatings to provide an approved flame spread rating. The Fire Safety Code


Board of Appeal & Review thereupon approved this product on September 9, 2003, as applied in accordance with the manufacturer's specifications.

LIMITATIONS: To be considered approved, this product must be installed and maintained in accordance with the manufacturer's specifications for the specific application.

Fire Safety Code Board of Appeal & Review



George S. Farrell
Chairman



Thomas B. Coffey, Esq.
Executive Director