



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 164.112/14/0

Expires: 17 March 2015

INTERIOR FINISH (IMO)

NOFIRE TECHNOLOGIES, INC.
21 INDUSTRIAL AVENUE
UPPER SADDLE RIVER NJ 07458

NoFire A-18 Fire Retardant Marine Paint is a ceramic intumescent fire retardant coating approved to a maximum dry thickness of 0.5 mm (0.02 in).

NoFire A-18 Paint was tested and approved in accordance with IMO Resolution MSC.61(67) (FTP Code) Part 5 of Annex 1 and did not require smoke and toxicity tests per Resolution MSC.61(67) (FTP Code) Annex 2, paragraph 2.2.

Identifying Data: SwRI Project No. 01.03071.01.015a dated January 2000 and SwRI Project No. 01.02500.075 dated October 2006.

This type approval is contingent on continuous compliance of the product verified via follow up services by Southwest Research Institute per follow- up Procedure Manual dated October 2006. Product shall be applied in accordance with the manufacturer's application procedure.

Valid for paints manufactured at the following location:
Amsterdam Color Works, Inc.
4808 Farragut Road
Brooklyn, NY 11203


Supersedes and extends certificate 164.112/14/0 dated 24 May 2005.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 17th DAY OF
MARCH 2010, AT WASHINGTON D.C.


K. J. HEINZ
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT